Minimum AWEF per equipment class

Equipment class	Minimum AWEF (Btu/W-h)
Dedicated condensing system – medium, indoor	5.61
Dedicated condensing system – medium, outdoor	7.60
Dedicated condensing system – low, indoor with a net capacity (q_{net}*) of:	
< 6,500 Btu/h	$9.091 \times 10^{-5} \times q_{net} + 1.81$
≥ 6,500 Btu/h	2.40
Dedicated condensing system – low, outdoor with a net capacity (q_{net}) of:	
< 6,500 Btu/h	$6.522 \times 10^{-5} \times q_{net} + 2.73$
≥ 6,500 Btu/h	3.15
Unit cooler – medium	9.00
Unit cooler – low, with a net capacity (q_{net}) of:	
< 15,500 Btu/h	$1.575 \times 10^{-5} \times q_{net} + 3.91$
≥ 15,500 Btu/h	4.15